# CONTRINEX

SENSOR TESTER
ATE-0000-010

HM 2511

- ✓ Fast field check of various sensor types
- ✓ LED and acoustic indicator
- ✓ Current supply to 100 mA
- ✓ Rechargeable battery
- ✓ Adapted to universal micro-USB charger

CE

123
106
22
61

GENERAL DATA

Sensor supply voltage	24 VDC
Max. sensor supply current	100 mA
Output types	PNP, NPN and push-pull
Current limit	✓
Rechargeable battery type	LiPo 9V (min 500 mAh)
Standard battery type	Alkaline 6LR61 9V
Rechargeable battery included	LiPo 9V 600 mAh
Battery life (600 mAh)	> 2 hours at 50 mA
Charging time (at 500 mA)	< 5 hours
Automatic switch off	After ~120 seconds of non-use
Enclosure rating	IP40
Weight (battery included)	96 g

INTERFACE

LED, green	Supply voltage
LED, green blinking (1 Hz)	Low battery (< 15% full)
LED, green blinking (4 Hz)	Charging, phase 1 (≤ 90% full)
LED, green blinking (2 Hz)	Charging, phase 2 (> 90% full)
LED, yellow	Output state
Micro-USB interface for charger	✓
Charger type (not included)	Universal mobile phone charger
Acoustic signal output off -> on	2'800 Hz
Acoustic signal output on -> off	2'400 Hz

AVAILABLE TYPES

Part number	Part reference	Description
600 000 033	ATE-0000-010	Sensor Tester with rechargeable battery LiPo 9V 600 mAh
622 000 016	AAL-0000-010	Additional rechargeable battery LiPo 9V 600 mAh

Note: additional suffix can appear to indicate a revision version or a special version.

These devices **must not be used** in applications where the **safety of people** is dependent on their functioning. Terms of delivery and rights to change design reserved.

HEMOMATIK

Nyckelvägen 7
142 50 SKOGÅS, Sweden

Tel: +46 (0)8 771 02 20
info@hemomatik.se

www.hemomatik.se